



January 10, 2020

Posted online

Request for Quotations
EPRFQ 2020-20071046

ADDENDUM #1

For the supply and delivery of 23 (twenty-three) King LED Model K118 Washington Acorn light fixtures or approved equivalent model

CLOSING: 12:00 PM ON January 14, 2020

Please refer to the above RFQ document in your possession and be advised of the following:

Part A: Revision

None

Part B: Questions and answers

Q1. Please provide specifier information for this project.

A1. The specification information is posted online with the call document. We have no additional information.

Q2. Please provide dimensions of the K13 post capital so we can determine the mounting requirements.

A2. There is a 7" diameter opening at the top where the fixture fits in. The weight of the fixture holds it in position then a thumb bolt is tightened so that it doesn't move.

Q3. Please clarify, your delivery date expectations due to the fact that the manufacturer's lead times for the fixture traditionally are between 6-8 weeks.

A3. It is understood that delivery will be impacted by manufacturer's lead time.

The deadline for questions on this RFQ has passed. There will be no further Addenda issued.

Should you have any questions regarding this Addendum, contact the undersigned via e-mail at purchasing@explace.on.ca

You must acknowledge receipt of this Addendum when submitting your quotation and be governed accordingly. All other aspects of this RFQ remain the same.

Sincerely,

T. Lynn Miller
Purchasing Manager