



March 24, 2020

Sent Via E-mail

Request for Tender
EP102-2020

ADDENDUM #4

HIGH VOLTAGE FEEDERS REPLACEMENT

CLOSING: 3:00 PM ON WEDNESDAY, APRIL 1, 2020

Please refer to the above RFT document in your possession and be advised of the following:

Part A: Clarification

None

Part B: Questions and answers

- Q1. Question about disposal of existing PILC cable. In order to prepare adequate removal and scrap of existing cable, therefore we need: Type, size and specification of existing cables needed to be removed. What is weight of cable Pound per Ft or KG per Meter?
- A1. An approximate 4.5 lb./ft can be considered. Refer to the drawings for the total length.
- Q2. In the drawings supplied by METSCO there is a discrepancy between two DWGs regarding starting point and MH nomenclature – please clarify.
- A2. Consider the worst case to cover the necessary costs. Details will be given upon Toronto Hydro's confirmation.

Should you have any questions regarding this addendum, contact the undersigned at 416-263-3628 or via e-mail at purchasing@explace.on.ca

Please attach this Addendum to your submission and be governed accordingly. All other aspects of the RFT remain the same.

Sincerely,

T. Lynn Miller
Purchasing Manager