



March 31, 2020

Notification Sent Via E-mail, and posted  
online

Request for Tender  
EP 101- 2020

ADDENDUM #7

Chiller Replacement at Enercare Centre

**CLOSING: Monday, April 6, 2020 at 3:00 PM**

Please refer to the above RFT document in your possession and be advised of the following:

Part A: Clarification

Part B: Questions and answers

Q1) Our Electrical Vendor has the below information request for this project:  
Can you advise the MCC Model Type, serial# and interrupting capacity for the unit. Can't seem to find this in the spec.

A1) MCC 5-1 Model Type: Klockner Moeller Series 200 Motor Control Centre  
MCC 5-1 Serial No. CDN-12-6912-0  
MCC 5-1 Interrupting Capacity: 42kA  
New Breaker to be 100A-3P 42kA LSI type.  
The successful contractor is required to do a Short Circuit Study as soon as contract award to confirm all electrical requirements.

**NOTE:** There will be no further Addenda issued for this Request for Tender.

Should you have any questions regarding this addendum, contact the undersigned at 416-263-3628 or via e-mail at [purchasing@explace.on.ca](mailto:purchasing@explace.on.ca)

Please attach this Addendum to your submission and be governed accordingly. All other aspects of the RFT remain the same.

Sincerely,

---

T. Lynn Miller  
Purchasing Manager