



April 23, 2019

Posted online

Request for Proposals
EPRFQ 2019-35061

ADDENDUM #2

For the provision of CCTV and security system repairs, maintenance and related services for a one-year term with three one-year options to renew

CLOSING: 10:00 AM ON MONDAY, MAY 6, 2019

Please refer to the above RFP document in your possession and be advised of the following:

Part A: Revision

None

Part B: Questions and answers

Q1. Are we able to be supplied drawings for all the sites in respect to this RFP?

A1. Drawings will be provided to the successful bidder following award.

Q2. With regard to the electrical work, is the union labour only required for the actual installation/replacement of hardware, or does the security-related portion also need to have and be represented by union employees or subcontractors?

A2. Electrical work refers to the installation and maintenance of all power requirements to the security devices; the security devices and related low voltage equipment does not require union labour.

Should you have any questions regarding this addendum, contact the undersigned at 416-263-3628 or via e-mail at purchasing@explace.on.ca

Please attach this Addendum to your submission and be governed accordingly. All other aspects of the RFP remain the same.

Sincerely,

T. Lynn Miller
Purchasing Manager